



Germanischer Lloyd

# Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. **94 579 - 90 HH**

Company **SELCO A/S**  
**Betonvej 10**  
**4000 Roskilde**

Product Description **Automatic Synchronizer**

Type **T4000**

Environmental Category **C**

Technical Data /  
Range of Application **Automatic Analog Synchronizer - Type T 4000**

Rated Voltage	100 - 660 V AC
Voltage Range	70 - 110 %
Rated Frequency	50/ 60 Hz
Frequency Difference	0.15Hz
Phase Angle	+/-6° to +/-9°

Contact Rating **380V AC / 8A 2000VA/ 150W DC**

Test Standard **Guidelines for the Performance of Type Approvals (2003)**

Documents **Test report : LK-Laboratory Test Report R 900703-01E**  
**Test Report Selco / Germanischer Lloyd 26.10.90**  
**Data Sheet 4095**

Remarks **None**

Valid until **2012-06-28**

Page **1 of 1**

Type Approval Symbol



File No. **I.L.03**

**Hamburg, 2007-06-29**

**Germanischer Lloyd**

Wolfgang Voß

Thomas Hartmann