

# Test Report



**DANAK**  
Reg. no. 19

---

## **Type approval testing of SIGMA Protection & Control modules S6000, S6100 and S6500**

### **Performed for Selco A/S**

DANAK-197219

Project no.: E501273-1

Page 1 of 29

6 annexes

16 October 2003

#### **DELTA**

*Danish Electronics,  
Light & Acoustics*

*Venlighedsvej 4  
2970 Hørsholm  
Denmark*

*Tel. (+45) 72 19 40 00  
Fax (+45) 72 19 40 01  
[www.delta.dk](http://www.delta.dk)*



|                       |  |
|-----------------------|--|
| <b>Title</b>          | Type approval testing of SIGMA Protection & Control modules S6000, S6100 and S6500   |
| <b>Test objects</b>   | SIGMA S6000, IO/P<br>SIGMA S6100, S/LS<br>SIGMA S6500, UI  |
| <b>Report no.</b>     | DANAK-197219   |
| <b>Project no.</b>    | E501273-1  |
| <b>Test period</b>    | 11 August to 3 October, 2003   |
| <b>Client</b>         | Selco A/S<br>Meterbuen 6-12<br>2740 Skovlunde<br>Denmark   |
| <b>Manufacturer</b>   | Selco A/S  |
| <b>Specifications</b> | <p>IACS E10: Corr.1 July 2003. Unified environmental test specification – Testing procedure for electrical control and monitoring, safety and protection, on board computer based systems and peripherals, loading instruments, internal communication and other electrical equipment as considered appropriate.</p> <p>IEC 60533: Second edition, 1999. “Electrical and electronic installations in ships – Electromagnetic compatibility”.</p> <p>EN 61000-6-2:1999. “Electromagnetic compatibility (EMC) part 6-2: Generic standards – Immunity for industrial environments”.</p> <p>EN 61000-6-4:2001. “Electromagnetic compatibility (EMC) – Part 6: Generic standards – Section 4: Emission standard for industrial environment”.</p> <p>EN 50263:1999. "Electromagnetic compatibility (EMC) – Product standard for measuring relays and protection equipment”</p> |
| <b>Results</b>        | No malfunctions were detected. The criteria for compliance are listed in <i>section 3.2</i> .  |

**Test personnel** Bjørn Larsen  
Henrik E. Nielsen  
Olling Truelsen  
Poul Terkelsen  
Niels Engel

**Date** 16 October 2003

**Project manager** 

---

Niels Engel  
DELTA

**Responsible** 

---

Kennet Palm, B.Sc.E.E.  
DELTA

| <b>Table of contents</b> |  | <b>Page</b> |
|--------------------------|--|-------------|
| <b>1.</b>                | <b>Summary of test</b>   | <b>6</b>    |
| 1.1                      | Test requirements  | 6           |
| 1.2                      | Conclusion   | 7           |
| 1.3                      | Modifications  | 7           |
| <b>2.</b>                | <b>Test specimen(s)</b>  | <b>8</b>    |
| 2.1                      | Test object – SIGMA S6000, IO/P- InputOutput & Protection module       | 8           |
| 2.2                      | Test object – SIGMA S6100, S/LS –Synchronization & Load Sharing module | 8           |
| 2.3                      | Test object – SIGMA S6500, UI – User Interface module                  | 8           |
| 2.4                      | AUX equipment – M4100 Alarm annunciator                                | 8           |
| 2.5                      | AUX equipment – M4100 Alarm annunciator                                | 8           |
| 2.6                      | AUX equipment – M3000 Analog alarm annunciator                         | 9           |
| 2.7                      | AUX equipment – Simulator box  | 9           |
| <b>3.</b>                | <b>General test conditions</b>   | <b>10</b>   |
| 3.1                      | Test set-up  | 10          |
| 3.2                      | Criteria for compliance  | 10          |
| 3.3                      | Functional test  | 10          |
| 3.4                      | Standard environment   | 11          |
| <b>4.</b>                | <b>Test and results</b>  | <b>12</b>   |
| 4.1                      | Visual inspection and performance                                      | 12          |
| 4.2                      | Conducted emission (CISPR 16-1)  | 13          |
| 4.3                      | Conducted emission (CISPR 11)  | 14          |
| 4.4                      | Radiated emission (CISPR 16-1)   | 15          |
| 4.5                      | Radiated emission (CISPR 11)   | 15          |
| 4.6                      | High voltage   | 16          |
| 4.7                      | Insulation resistance  | 16          |
| 4.8                      | Vibration  | 17          |
| 4.8.1                    | Resonance search   | 17          |
| 4.8.2                    | Endurance vibration  | 18          |
| 4.9                      | Power supply variations  | 19          |
| 4.10                     | Power supply failure   | 19          |
| 4.11                     | Conducted low frequency interference                                   | 20          |
| 4.12                     | Conducted radio frequency interference                                 | 21          |
| 4.13                     | Radiated radio frequency interference                                  | 22          |
| 4.14                     | Surge voltage  | 23          |
| 4.15                     | Electrostatic discharge  | 24          |
| 4.16                     | Fast transients (burst)  | 25          |
| 4.17                     | 1 MHz burst  | 26          |
| 4.18                     | Dry heat   | 27          |
| 4.19                     | Low temperature (cold)   | 28          |
| 4.20                     | Damp heat, cyclic  | 29          |

Annex 1 List of instruments (2 pages)

Annex 2 Photos (9 pages)

Annex 3 Test set-up, system briefing and functional test procedure  
(from Selco A/S ) (8 pages)

Annex 4 Test record sheets – Conducted emissions (24 pages)

Annex 5 Test record sheets – Radiated emissions (8 pages)

Annex 6 Explanatory notes regarding modifications (from Selco A/S)  
(2 pages)

## 1. **Summary of test**

### 1.1 **Test requirements**

| <b>Test</b>                            | <b>Test method</b>                   |
|--|--------------------------------------|
| Visual inspection                      | IACS E10:2003                        |
| Performance test                       | IACS E10:2003                        |
| Power supply variations                | IEC 60945:2002 / IACS E10:2003       |
| Power supply failure                   | IEC 60945:2002 / IACS E10:2003       |
| Power supply dips and interruptions    | IEC 61000-4-11:1994                  |
| Conducted low frequency interference   | IEC 60533:1999 / IEC 61000-4-16:1998 |
| Conducted radio frequency interference | EN 61000-4-6:2001                    |
| Electrical fast transients (burst)     | EN 61000-4-4:1995                    |
| Electrostatic discharges               | EN 61000-4-2:2001                    |
| Radiated radio frequency interference  | EN 61000-4-3:2002                    |
| Surge transients                       | EN 61000-4-5:2001                    |
| Conducted emissions                    | CISPR 16-1:1999 / CISPR 11:1999      |
| Radiated emissions                     | CISPR 16-1:1999 / CISPR 11:1999      |
| 1 MHz burst                            | IEC 60255-22-1:1988                  |
| Vibration (resonance search)           | IEC 60068-2-6:1995                   |
| Vibration (random)                     | IEC 60068-2-64:1993                  |
| Insulation resistance                  | IACS E10:2003                        |
| High voltage                           | IACS E10:2003                        |
| Dry heat                               | IEC 60068-2-2:1984 + Amendments      |
| Low temperature (cold)                 | IEC 60068-2-1:1990 + Amendments      |
| Damp heat (cyclic)                     | IEC 60068-2-30 1980 + Amendments     |

## 1.2 **Conclusion**

The test objects mentioned in this report meet the relevant requirements of the standards stated below.

- IACS E10:2003
- IEC 60533:1999
- EN 61000-6-2:1999
- EN 61000-6-4:2001
- EN 50263:1999

The test results relate only to the specimens tested.

## 1.3 **Modifications**

The test specimens were modified before they passed the conducted radio frequency interference testing, the surge testing, the electrostatic discharge testing and the radiated emission measurements. Thus the test results mentioned in *chapter 4* apply to the modified test specimens only.

Detailed explanatory notes regarding the modifications are given in *annex 6*.

## **2. Test specimen(s)**

### **2.1 Test object – SIGMA S6000, IO/P- InputOutput & Protection module**

|                  |                                   |
|------------------|-----------------------------------|
| Manufacturer     | Selco A/S                         |
| Model / type     | SIGMA S6000                       |
| Part no.         | S6000-00                          |
| Serial no.       | -                                 |
| Supply voltage   | 24 VDC                            |
| Operational mode | Simulated normal operational mode |

### **2.2 Test object – SIGMA S6100, S/LS –Synchronization & Load Sharing module**

|                  |                                   |
|------------------|-----------------------------------|
| Manufacturer     | Selco A/S                         |
| Model / type     | SIGMA S6100                       |
| Part no.         | S6100-00                          |
| Serial no.       | -                                 |
| Supply voltage   | 24 VDC                            |
| Operational mode | Simulated normal operational mode |

### **2.3 Test object – SIGMA S6500, UI – User Interface module**

|                  |                                   |
|------------------|-----------------------------------|
| Manufacturer     | Selco A/S                         |
| Model / type     | SIGMA S6500                       |
| Part no.         | S6500-00                          |
| Serial no.       | -                                 |
| Supply voltage   | 24 VDC                            |
| Operational mode | Simulated normal operational mode |

### **2.4 AUX equipment – M4100 Alarm annunciator**

|              |           |
|--------------|-----------|
| Manufacturer | Selco A/S |
| Model / type | M4100     |
| Part no.     | M4100-22  |
| Serial no.   | 365308    |

### **2.5 AUX equipment – M4100 Alarm annunciator**

|              |           |
|--------------|-----------|
| Manufacturer | Selco A/S |
| Model / type | M4100     |
| Part no.     | M4100-22  |
| Serial no.   | 365310    |



**2.6     *AUX equipment – M3000 Analog alarm annunciator***

|              |                    |
|--------------|--------------------|
| Manufacturer | Selco A/S          |
| Model / type | M3000, 24 Channels |
| Part no.     | M3000-30           |
| Serial no.   | 332916             |

**2.7     *AUX equipment – Simulator box***

|              |                         |
|--------------|-------------------------|
| Manufacturer | Selco A/S               |
| Model / type | JBH / analogue switches |
| Part no.     | -                       |
| Serial no.   | -                       |

### **3. General test conditions**

#### **3.1 Test set-up**

A description and a drawing of the test set-up are enclosed in *annex 3*.

#### **3.2 Criteria for compliance**

No change of the actual operational states of the SIGMA S6000, S6100 and S6500 are allowed. However, temporary change of operational state is allowed during the power supply failure test, provided that normal power-up procedure is obtained after the exposures.

In addition, the following acceptance criteria for compliance regarding accuracy of analogue parameters were in force:

- "VOLT":  $\pm 0.5$  mA
- "VOLT":  $\pm 0.5$  V
- "SPEED":  $\pm 0.5$  mA
- "SPEED":  $\pm 0.5$  V
- "Analog output":  $\pm 0.5$  mA
- "Analog output":  $\pm 0.5$  V
- "KW":  $\pm 0.5$  V
- "KVar":  $\pm 0.3$  V

#### **3.3 Functional test**

A functional test was performed before, during (if specified) and after each test. The functional test was carried out in accordance with the functional test procedure provided by the customer.

The functional test procedure is given in *annex 3*.

### **3.4 Standard environment**

Normal environmental condition:

|                      |   |   |
|----------------------|---|---|
| Temperature          | : | 15°C to 35°C                              |
| Humidity             | : | 25 %RH to 75 %RH                          |
| Air pressure         | : | 86 kPa to 106 kPa (860 mbar to 1060 mbar) |
| Power supply voltage | : | $U_{\text{nom.}} \pm 3\%$                 |

## **4. Test and results**

### **4.1 Visual inspection and performance**

#### **Specification**

IACS E10, Test No. 1 and 2

#### **Procedure**

The conformance to drawings and the functional performance are demonstrated to the society surveyors present at DELTA during the type approval testing.

The functional test is also demonstrated.

#### **Results**

The conformance to drawings and the functional performance, including the functional test procedure are demonstrated to the society surveyors after the completion of the type approval testing.

## 4.2 **Conducted emission (CISPR 16-1)**

### **Specifications**

CISPR 16-1 (1999-10): Specification for radio disturbance and immunity measuring apparatus and methods - Part 1: Radio disturbance and immunity measuring apparatus.

### **Severity and procedure**

(IACS E10:2003 & IEC 60533:1999 – Power distribution zone)

|                     |   |               |                     |
|---------------------|---|---------------|---------------------|
| Frequency range     | : | 0.01-30 MHz   |                     |
| Limits (quasi-peak) | : | 0.01-0.15 MHz | : 120-69 dB $\mu$ V |
|                     |   | 0.15-0.50 MHz | : 79 dB $\mu$ V     |
|                     |   | 0.50-30 MHz   | : 73 dB $\mu$ V     |

The radio frequency voltage is measured at the power supply terminals of the test specimens, by a receiver through an artificial mains network.

The test specimens are energised and in normal operational mode during the measurement

### **Results**

The conducted emissions were within the specified limits. Test record sheets of the conducted emission measurements are enclosed in *annex 4*.

### 4.3 **Conducted emission (CISPR 11)**

#### **Specification**

CISPR 11 (1999-08): Industrial, scientific and medical (ISM) radio-frequency equipment - Electromagnetic disturbance characteristics - Limits and methods of measurement.

#### **Severity and procedure**

|                     |   |               |                            |
|---------------------|---|---------------|----------------------------|
| Frequency range     | : | 0.15-30 MHz   |                            |
| Limits (quasi-peak) | : | 0.15-0.50 MHz | : 79 dB $\mu$ V quasi-peak |
|                     |   |               | : 66 dB $\mu$ V average    |
|                     |   | 0.50-30 MHz   | : 73 dB $\mu$ V quasi-peak |
|                     |   |               | : 60 dB $\mu$ V average    |

The radio frequency voltage is measured at the power supply terminals of the test specimen, by a receiver through an artificial mains network.

The test specimen is energised and in normal operational mode during the measurement.

#### **Results**

The conducted emissions were within the specified limits. Test record sheets of the conducted emission measurements are enclosed in *annex 4*.

#### 4.4 **Radiated emission (CISPR 16-1)**

##### **Specifications**

CISPR 16-1 (1999-10): Specification for radio disturbance and immunity measuring apparatus and methods - Part 1: Radio disturbance and immunity measuring apparatus.

##### **Severity and procedure**

(IACS E10:2003 & IEC 60533:1999 – Power distribution zone)

|                     |   |               |                               |
|---------------------|---|---------------|-------------------------------|
| Frequency range     | : | 0.15-2000 MHz |                               |
| Limits (quasi-peak) | : | 0.15-30 MHz   | : 80-50 dB $\mu$ V/m          |
|                     |   | 30-100 MHz    | : 60-54 dB $\mu$ V/m          |
|                     |   | 100-2000 MHz  | : 54 dB $\mu$ V/m, except for |
|                     |   | 156-165 MHz   | : 24 dB $\mu$ V/m             |

The electric field is measured with antennas at a distance of 3 m.

The test specimens are energised and in normal operational mode during the measurement.

##### **Results**

The radiated emissions were within the specified limits. Test record sheets of the radiated emission measurements are enclosed in *annex 5*.

#### 4.5 **Radiated emission (CISPR 11)**

##### **Specifications**

CISPR 11 (1999-08): Industrial, scientific and medical (ISM) radio-frequency equipment - Electromagnetic disturbance characteristics - Limits and methods of measurement.

##### **Severity and procedure**

|                     |   |              |                   |
|---------------------|---|--------------|-------------------|
| Frequency range     | : | 30-1000 MHz  |                   |
| Limits (quasi-peak) | : | 30-230 MHz   | : 40 dB $\mu$ V/m |
|                     |   | 230-1000 MHz | : 47 dB $\mu$ V/m |

The electric field is measured with antennas at a distance of 10 m.

The test specimen is energised and in normal operational mode during the measurement.

##### **Results**

The radiated emissions were within the specified limits. Test record sheets of the radiated emission measurements are enclosed in *annex 5*.

## 4.6 High voltage

### Specification

IACS E10, Test No. 10

### Procedure

550 VAC, 50 Hz is applied between shorted supply terminals and earth for 1 minute. No flashover, breakdown, etc. is acceptable.

### Results

| Cable designation                                      | Test condition  | Test voltage [Vrms] | Duration [sec. or msec.] | Remarks (Description of reaction)  |
|--|---|---------------------|--------------------------|--|
| DC Power (24 VDC)                                      | Test voltage injected between shorted supply leads and protective earth | 550 VAC             | 60 sec.                  | No flashover or breakdown was observed during the exposure. The insulation resistance was OK after the exposure. |
| Note: Protection components removed prior to exposure. |   |                     |                          |  |

## 4.7 Insulation resistance

### Specification

IACS E10, Test No. 9

### Procedure

The insulation resistance is measured between shorted supply terminals and earth with 50 VDC. The insulation resistance is to be above 10 MΩ initially, and above 1 MΩ after the low temperature, the damp heat and the high voltage exposures.

### Results

| Cable designation   | Test condition              | Test voltage [Vrms] | Duration [sec] | Insulation resistance [M Ohms] |
|---|-----------------------------|---------------------|----------------|--------------------------------|
| DC Power (24 VDC)   | Before High voltage test    | 50 VDC              | 60 sec.        | > 1000 M Ohms                  |
|   | After High voltage test     | 50 VDC              | 60 sec.        | > 1000 M Ohms                  |
|   | Before Low temperature test | 50 VDC              | 60 sec.        | > 1000 M Ohms                  |
|   | After Low temperature test  | 50 VDC              | 60 sec.        | > 1000 M Ohms                  |
|   | Before Damp heat test       | 50 VDC              | 60 sec.        | > 1000 M Ohms                  |
|   | After Damp heat test        | 50 VDC              | 60 sec.        | > 160 M Ohms                   |
| Note: Protection components removed prior to measurement. |                             |                     |                |                                |



## **4.8**     **Vibration**

### **4.8.1**   **Resonance search**

#### **Specifications**

IEC 60068-2-6 (1985), Test Fc: Vibration (sinusoidal).

#### **Severity and procedure**

|                     |   |                          |               |
|---------------------|---|--------------------------|---------------|
| Frequency range     | : | 2-100 Hz                 |               |
| Frequency/amplitude | : | 2-25 Hz                  | :     ±1.6 mm |
|                     |   | 25-100 Hz                | :     ±4.0 g  |
| Sweep rate          | : | Max. 1 octave/min.       |               |
| Number of axes      | : | 3 mutually perpendicular |               |

The test specimens are de-energised during the exposure.

During the resonance search, the resonance frequencies are determined by means of stroboscopic light with slow-motion facility and accelerometer measurements of the amplification factors (Q).

Resonance frequencies with an amplification factor above 2 are recorded.

#### **Results**

No amplification factors above 2 were recorded.

#### **4.8.2 Endurance vibration**

The sinusoidal vibration test according to IACS E10 is replaced by random vibration test according to Certification Notes No. 2.4, issued May 1995 by DNV.

This random vibration test will cover the requirements of the sinusoidal vibration test according to IACS E10.

##### **Specification**

IEC 60068-2-64 (1993), Test Fh: Vibration, broadband random (digital control).

##### **Severity and procedure**

|                       |   |                          |                          |
|-----------------------|---|--------------------------|--------------------------|
| Frequency range       | : | 2-100 Hz                 |                          |
| Acceleration spectral | : | 2-25 Hz                  | : +12 dB/octave          |
| Density               | : | 25-100 Hz                | : 0.2 g <sup>2</sup> /Hz |
| Total RMS level       | : | 4.0 g                    |                          |
| Duration              | : | 150 minutes per axis     |                          |
| Number of axes        | : | 3 mutually perpendicular |                          |

The test specimens are energised and in normal operational mode during the exposures. A functional test is performed after the exposure in each axis.

A visual inspection is performed after the exposure.

##### **Results**

No malfunction was observed during the exposure and the function of the test specimens was OK after the exposure in each axis.

No damage was observed after the exposures.

#### **4.9 Power supply variations**

##### **Specifications**

IACS E10, Test No. 4

IEC 60945, Section 5.2.2

##### **Procedure (24 VDC supplied)**

$U_{\text{nom.}} = \text{Nominal supply voltage} = 24 \text{ VDC}$

Exposures, each with a duration of 15 minutes, are performed at the following supply voltages:

$U_1 = U_{\text{n}+30\%} = 31.2 \text{ VDC}$

$U_2 = U_{\text{n}-25\%} = 18.0 \text{ VDC}$

The test specimens are observed during the exposures, and a functional test is performed at the end of each exposure.

An additional power supply variations test is performed as part of the functional test during the low temperature and the dry heat test profiles.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.

#### **4.10 Power supply failure**

##### **Specifications**

IACS E10, Test No. 3

##### **Procedure**

The power supply is interrupted 3 times within 5 minutes with a break time of 60 seconds.

Normal power-up procedure is to be obtained after each power break.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after each exposure.

#### **4.11 Conducted low frequency interference**

##### **Specifications**

IEC 61000-4-16 (1998-01): Test for immunity to conducted, common mode disturbances in the frequency range 0 Hz to 150 kHz.

##### **Severity and procedure**

|                         |   |               |                                  |
|-------------------------|---|---------------|----------------------------------|
| Frequency range         | : | 0.05 - 10 kHz |                                  |
| Amplitude (DC-supplied) | : | 0.05 - 10 kHz | : 10% of $U_{nom.}$ / min.3 Vrms |
| Maximum applied power   | : | 2.0 W         |                                  |

The impedance of the test generator is less than 1  $\Omega$ .

The test signal is superimposed on the power supply lines via a coupling transformer.

The test specimens are energised and in normal operational mode during the exposure. The test specimens are observed during the exposure, and a functional test is performed after the exposure.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.

## 4.12 **Conducted radio frequency interference**

### **Specifications**

IEC 61000-4-6 (2001-04), Ed. 1.1: Testing and measurement techniques - Immunity to conducted disturbances, induced by radio-frequency fields.

### **Severity and procedure**

|                 |   |   |
|-----------------|---|---|
| Frequency range | : | 150 kHz - 80 MHz                                    |
| Amplitude       | : | 0.15-80 MHz : 10 Vrms                               |
| Modulation      | : | 80% AM, 400 Hz sine wave<br>80% AM, 1 kHz sine wave |

The test specimen is supplied with power via a coupling/decoupling network.

The test signal is coupled to the power lines and signal lines via coupling networks. The coupling impedance is 150  $\Omega$ .

The test specimens are energised and in normal operational mode during the exposure. The test specimens are observed during the exposure, and a functional test is performed after the exposure.

### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.

#### **4.13 Radiated radio frequency interference**

##### **Specifications**

IEC 61000-4-3 (2002-03): Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test.

##### **Severity and procedure**

|                 |   |                          |
|-----------------|---|--------------------------|
| Frequency range | : | 80-2000 MHz              |
| Field strength  | : | 10 V/m                   |
| Modulation      | : | 80% AM, 400 Hz sine wave |
|                 | : | 80% AM, 1 kHz sine wave  |

The test is performed in a semi-anechoic room. The field is generated using linearly polarised broadband antennas.

The test specimens are energised and in normal operational mode during the exposure. The test specimens are observed during the exposure, and a functional test is performed after the exposure.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.

#### **4.14 Surge voltage**

##### **Specification**

IEC 61000-4-5 (2001-04) Ed. 1.1: Testing and measurement techniques - Surge immunity test.

##### **Severity and procedure**

|                          |   |   |
|--------------------------|---|---|
| Amplitude AC power lines | : | 1 & 2 kV line-to-earth, 0.5 & 1 kV line-to-line |
| Amplitude signal lines   | : | 1 kV line-to-earth (lines >30 m)                |
| Voltage rise time        | : | 1.2 $\mu$ s (open circuit)                      |
| Voltage decay time       | : | 50 $\mu$ s (open circuit)                       |

The impedance of the test generator is 2  $\Omega$  for line-to-line coupling and 12  $\Omega$  for line-to-earth coupling.

The impedance of the test generator is 2  $\Omega$ , for exposures on shielded signal lines.

The test specimens are supplied with power via a transient coupling network.

The test specimens are energised and in normal operational mode during the exposure. The test specimens are observed during the exposure, and a functional test is performed after the exposure.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.

#### **4.15 Electrostatic discharge**

##### **Specifications**

IEC 61000-4-2 (2001-04) Ed. 1.2: Testing and measurement techniques - Electrostatic discharge immunity test.

##### **Severity and procedure**

|                            |   |                                    |
|----------------------------|---|------------------------------------|
| Air discharge              | : | 2, 4 and 8 kV                      |
| Contact discharge          | : | 2, 4 and 6 kV                      |
| Energy storage capacitance | : | 150 pF                             |
| Discharge resistance       | : | 330 $\Omega$                       |
| Polarity                   | : | + and -                            |
| Number of discharges       | : | 10 per polarity at each test point |

The discharges are applied only to such points and surfaces of the test specimen, which are accessible to personnel during normal use.

Contact discharges are applied to conductive surfaces and coupling planes, and air discharges are applied to insulating surfaces.

The test specimens are energised and in normal operational mode during the exposure. The test specimens are observed during the exposure, and a functional test is performed after the exposure.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.



#### 4.16 **Fast transients (burst)**

##### **Specifications**

IEC 61000-4-4 (1995-01): Testing and measurement techniques - Section 4: Electrical fast transient/burst immunity test, Amendment 1 (2000-11), Amendment 2 (2001-07).

##### **Severity and procedure**

|                     |   |   |
|---------------------|---|---|
| Amplitude           | : | 2 kV on power lines<br>1 kV on signal lines |
| Pulse rise time     | : | 5 ns  |
| Pulse duration      | : | 50 ns                                       |
| Generator impedance | : | 50 $\Omega$                                 |
| Repetition rate     | : | 5 kHz                                       |
| Burst duration      | : | 15 ms                                       |
| Burst period time   | : | 300 ms                                      |

The test specimens are supplied with power via a transient coupling network. The test signal is successively coupled to each power line and protective earth with reference to the ground plane.

The test signal is injected on the signal lines using a capacitive coupling clamp. The clamp is successively used on selected signal cables.

The test signal is injected on the power lines for 5 minutes, using each coupling mode and each polarity, and then on the signal lines for 5 minutes using each polarity.

The test specimens are energised and in normal operational mode during the exposure. The test specimens are observed during the exposure and a functional test is performed after the exposure.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.

#### **4.17 1 MHz burst**

##### **Specifications**

IEC 60255-22-1 (1988):Electrical disturbance tests for measuring relays and protection equipment. Part 1: 1 MHz burst disturbance tests.

##### **Severity and procedure**

|                      |   |  |
|----------------------|---|--|
| Amplitude            | : | 1 kV DM on power ports and I/O ports<br>2.5 kV CM on power ports and I/O ports<br>1 kV CM on communication ports |
| Frequency            | : | 1 MHz  |
| Source impedance     | : | 200 Ohm  |
| Rise time            | : | 75 ns  |
| Repetition frequency | : | 400 Hz   |

The test specimen is energised and in normal operational mode during the exposure. The test specimen is observed during the exposure and a functional test is performed after the exposure.

##### **Results**

No malfunction was observed during the exposure, and the function of the test specimens was OK after the exposure.

#### **4.18 Dry heat**

##### **Specification**

IEC 60068-2-2 (1974), Test Bd: Dry heat for heat-dissipating specimen with gradual change of temperature, Amendment 1 (1993), Amendment 2 (1994).

##### **Severity and procedure**

The following two exposures are performed:

1. Temperature : 55°C  
Duration : 16 hours  
Humidity : Below 50 %RH
2. Temperature : 70°C  
Duration : 2 hours  
Humidity : Below 50 %RH

The test specimens are energised and in normal operating condition during the exposure. During the last hour of the exposure, a functional test is performed.

After recovery the functional test is repeated in standard environment.

##### **Results**

No malfunction was observed during the exposure and the function of the test specimen was OK during the last hour of the exposure and after recovery.

#### **4.19 Low temperature (cold)**

##### **Specifications**

IEC 60068-2-1 (1990), Test Ad: Cold for heat-dissipating specimen with gradual change of temperature, Amendment 1 (1993), Amendment 2 (1994).

##### **Severity and procedure**

The following two exposures are performed:

1. Temperature : -15°C  
Duration : 16 hours
2. Temperature : -25°C  
Duration : 2 hours

The test specimens are de-energised during the exposure. However, during the last hour of the exposure the test specimen is energised and a functional test is performed. After recovery a functional test and an insulation resistance test are performed in standard environment.

##### **Results**

No malfunction was observed during the exposure and the function of the test specimen was OK during the last hour of the exposure and after recovery.

## 4.20 **Damp heat, cyclic**

### **Test specification**

IEC 60068-2-30 (1980), Test Db: Damp heat cyclic (12 + 12 hours' cycle), Variant 1, Amendment 1 (1985).

### **Severity and procedure**

|                               |   |         |
|-------------------------------|---|---------|
| Lower temperature             | : | 25°C    |
| Humidity at lower temperature | : | >95 %RH |
| Upper temperature             | : | 55°C    |
| Humidity at upper temperature | : | 93 %RH  |
| Number of cycles              | : | 2       |

During the first cycle, the test specimens are energised and in normal operational mode. A functional test is performed during the first 2 hours of the 55°C phase.

During the second cycle, the test specimens are de-energised. However, during the last 2 hours of the second 55°C phase the test specimens are energised and a functional test is performed.

After recovery the test specimens are energised and a functional test and an insulation resistance test are performed in standard environment.

### **Results**

No malfunction was observed during the exposure, and the function of the test specimen was OK during the first and second cycle at 55°C and 93 %RH, and after recovery.

No corrosion attack was observed after the exposure.

***Annex 1***

***List of instruments***

***(2 pages)***

### List of instruments

| NO.      | DESCRIPTION                                   | MANUFACTURER        | TYPE NO.                     |
|----------|---|---------------------|------------------------------|
| 22631    | VIBRATION CONTROLLER                          | SIGNAL STAR VECTOR  | U2 Sys 5144                  |
| ACC. 91  | ACCELEROMETER                                 | BRUEL & KJÆR        | 4371                         |
| ACC. 93  | ACCELEROMETER                                 | BRUEL & KJÆR        | 4371                         |
| ACC.71A  | ACCELEROMETER                                 | BRUEL & KJÆR        | 4393                         |
| ACC. 72  | ACCELEROMETER                                 | BRUEL & KJÆR        | 4393                         |
| 22630    | ACCELEROMETER PREAMPLIFIER                    | BRUEL & KJÆR        | 2692                         |
| 22589    | ACCELEROMETER PREAMPLIFIER                    | BRUEL & KJÆR        | 2626                         |
| 22601    | ELECTRONIC VOLTMETER                          | HEWLETT-PACKARD     | 34401A                       |
| 22591    | OSCILLOSCOPE                                  | KENWOOD             | CS-1025                      |
| Y221     | ELECTRODYNAMIC SHAKER                         | LING DYNAMIC SYS.   | V 875-440T                   |
| U2501    | SWITCHING POWER AMPLIFIER                     | LING DYNAMIC SYS.   | SPA 50/30KCE                 |
| EVFGT-27 | CLIMATIC TEST CHAMBER                         | DELTA               | VKF10                        |
| EVFGT-28 | CLIMATIC TEST CHAMBER                         | DELTA               | VF10                         |
| 29223    | CURRENT PROBE                                 | SINGER              | 91550-4                      |
| 29342    | REFLECTOMETER COUPLER, 600-4200 MHz           | ROHDE & SCHWARZ     | ZPD                          |
| 29347    | RF GENERATOR , 10 kHz-1 GHz                   | MARCONI             | 2022                         |
| 29461    | ARTIFICIAL MAINS NETWORK                      | ROHDE & SCHWARZ     | ESH2/Z5                      |
| 29680    | IMPULSE VOLTAGE LIMITER                       | ROHDE & SCHWARZ     | ESH3/Z2                      |
| 29691    | 0.01 - 20 GHz. SYNTH. SWEEPER                 | HEWLETT-PACKARD     | 83620A                       |
| 29694    | 1-12 GHz. HORN ANTENNA.                       | LOGIMETRICS         | AN 8200 F                    |
| 29703    | LF POWER AMPLIFIER                            | BRUEL & KJÆR        | 2708                         |
| 29754    | RF POWER ATTENUATOR, 50 OHM, 6 dB, 150 W      | NARDA               | 769-6                        |
| 29781    | DIGITAL MULTIMETER W. HPIB                    | HEWLETT-PACKARD     | 34401A                       |
| 29786    | HIGH POWER RF AMPLIFIER, 80-1000 MHz          | AMPLIFIER RESEARCH  | 500W1000M5                   |
| 29797    | BILOG ANTENNA, 30-1000 MHz                    | CHASE ELECTRICS LTD | CBL 6111A                    |
| 29815    | 3-LINE CDN NETWORK,<br>IEC 61000-4-6          | MEB                 | M3                           |
| 29749    | SHIELD-LINE CDN NETWORK,<br>IEC 61000-4-6     | DELTA EMC DEPT.     | SHIELD LINE<br>CDN           |
| 29827    | ELECTRONIC SURGE GENERATOR                    | EM TEST             | VCS 500                      |
| 29832    | DIFFERENTIAL HIGH VOLTAGE PROBE,<br>DC-25 MHz | TEKTRONIX           | P5200                        |
| 29838    | ESD GENERATOR, AIR AND CONTACT DIS-<br>CHARGE | KEYTEK              | MZ-15EC                      |
| 29844    | -40 dBc VOLTAGE SAMPLER, DC-100 MHz           | DELTA EMC DEPT.     | SAMPLER<br>VER. 2            |
| 29846    | RF GENERATOR, 9 kHz-2.4 GHz                   | MARCONI             | 2024                         |
| 29861    | EMI-SOFTWARE Ver. 1.60                        | ROHDE & SCHWARZ     | ES-K1, PART:<br>1026.6790.02 |
| 29865    | CAPACITIVE COUPLING CLAMP                     | DELTA EMC           | IEC 1000-4-4                 |

| NO.   | DESCRIPTION  | MANUFACTURER       | TYPE NO.                |
|-------|--|--------------------|-------------------------|
| 29866 | LF INJECTION TRAF0, 6 x 6 TURNS                    | KNUD OVERGAARD     | 14311                   |
| 29880 | CURRENT PROBE AMPLIFIER FOR 29907 AND 29707        | TEKTRONIX          | AM503B                  |
| 29884 | PULSE / FUNCTION GENERATOR, 50 MHz                 | WAVETEK            | 81                      |
| 29904 | BROADBAND POWER AMPLIFIER, 10 kHz-250 MHz, 75 W    | AMPLIFIER RESEARCH | 75A250                  |
| 29906 | 15 MHz FUNCTION / ARBITRARY WAVE GENERATOR         | HEWLETT-PACKARD    | 33120A                  |
| 29907 | ACTIVE CURRENT PROBE HEAD FOR 29880                | TEKTRONIX          | A6302                   |
| 29913 | ELECTRICAL FAST TRANSIENT (BURST) GENERATOR        | EM TEST            | EFT 500                 |
| 29915 | DC COUPLED POWER AMPLIFIER / POWER SUPPLY          | HEWLETT-PACKARD    | 467A                    |
| 29916 | AUTOMATIC TEST RECEIVER, 9 kHz-2.75 GHz            | ROHDE & SCHWARZ    | ESCS 30<br>1102.4500.30 |
| 29936 | SAMPLING OSCILLOSCOPE, 100 MHz, 500 MS/s           | TEKTRONIX          | TDS 340A                |
| 29967 | COAX RF DIODE DETECTOR, NEG. OUTPUT, ROOM 5        | HEWLETT-PACKARD    | 8471D                   |
| 29975 | DIGITAL MULTIMETER w. GPIB                         | HEWLETT-PACKARD    | 34401A                  |
| 29984 | RF POWER AMPLIFIER, 0.8-2.2 GHz, 200W              | MILMEGA            | AS0822-200              |
| 29985 | BILOG ANTENNA 26-2000 MHz                          | SCHAFFNER/CHASE    | 6140A                   |
| 49002 | SINGLE CHANNEL POWER METER DISPLAY UNIT            | ROHDE & SCHWARZ    | NRVS                    |
| 49003 | THERMAL POWER SENSOR, DC-18 GHz                    | ROHDE & SCHWARZ    | NRV-Z51                 |
| 49024 | COAX RF DIODE DETECTOR, NEG. OUTPUT, CS TEST       | HEWLETT-PACKARD    | 8471D                   |
| 49034 | "CABLE#42", 3 M, 50 OHM COAX CABLE, N-N (STRAIGHT) | CELLFLEX           |                         |
| 29332 | ACTIVE LOOP ANTENNA                                | ROHDE & SCHWARZ    | HFH-Z2                  |
| 43028 | MEGGER   | AVO INTERNATIONAL  | BM 80                   |
| 30344 | HIGH VOLTAGE APPARATUS                             | WILLY NIELSEN      | W5                      |
| 49007 | HFD-RELAY TESTER / 1 MHz BURST                     | HAEFELY            | P3                      |



***Annex 2***  
***Photos***  
***(9 pages)***




PHOTO 1. Conducted low frequency interference.




PHOTO 2. Conducted radio frequency interference.



PHOTO 3. Conducted radio frequency interference.



PHOTO 4. Electrostatic discharge. (e.g. S6500).




PHOTO 5. Electrical fast transients (burst).




PHOTO 6. Surge transients (e.g. S6000).




PHOTO 7. Conducted emission. (e.g. CISPR 16-1).



PHOTO 8. Radiated emission (3 m).



PHOTO 9. Radiated emission (3 m).



PHOTO 10. Radiated emission (3 m).



PHOTO 11. Radiated emission (10 m).




PHOTO 12. Climatic testing (low temperature, dry heat and damp heat).




PHOTO 13. Vibration testing (resonance search), e.g. S6000.




PHOTO 14. Vibration testing (endurance).





PHOTO 15. Radiated radio frequency interference (80-1000 MHz).



PHOTO 16. Radiated radio frequency interference (1000-2000 MHz).




PHOTO 17. 1 MHz burst (e.g. S6000).





PHOTO 18. 1 MHz burst (e.g. S6000).

***Annex 3***

***Test set-up, system briefing and functional test procedure  
(from Selco A/S)***

***(8 pages)***

**Test set-up**



**All cables  
unshielded**

## System briefing

### S6000 SIGMA IO/P Module



SIGMA is an integrated generator protection and control system. Ease of use, quality and cost effectiveness were the key targets when SELCO set out to design the SIGMA concept.

The SELCO S6000 SIGMA IO/P Module provides data acquisition and complete protection for a single generator. The S6000 measures the voltages across all three phases as well as the current running through each phase. The voltage and current signals are digitally sampled by the built-in signal processor and converted to true RMS values. The S6000 will continuously do real-time calculations of voltage, current, frequency, active/reactive power, VA, power factor etc. The S6000 can connect to generators with or without neutral. The S6000 includes six programmable protection functions: Short Circuit, Over Current, Reverse Power, Overload, Excitation Loss and Voltage Establishment. The protection functions can be configured with regard to trip level, delay and relay function. The protection works on all three phases. A dedicated LED and open collector output is provided for each protection function.

Load shedding can be done at two individual levels. Each level controls a dedicated built-in relay. Measured and calculated parameters can be provided as VDC and mA signals on three isolated analogue outputs. The span of each analogue output is programmable. The RS485 MODBUS-RTU connection provides easy interfacing to SCADA systems and PLC's. Measured calculated parameters are easily accessed by any device capable of operating as a MODBUS master. Configuration parameters can also be accessed and altered through MODBUS-RTU. An RS232 connection is provided for point-to-point configuration. The S6000 can be remotely configured by "clear text" commands issued from a standard terminal emulator (e.g. Windows HyperTerminal). The complete configuration can be stored as text files.

Together with the S6100 and S6500, the S6000 will provide a simple yet powerful solution to a full scale control system. Such a system will provide protection, auto-synchronization, load sharing, indication and SCADA connectivity.

A single variant supports nominal voltages in the range 63 to 690 VAC. Secondary CT current must be specified upon delivery (5 or 1 A).

The S6000 is designed to comply with marine requirements. The design of the circuitry and metal casing provides the best possible protection from EMC and environmental stress. The S6000 is intended for switch board installation. Measurements are 145 x 190 x 64 mm.

## S6100 SIGMA S/LS Module



SIGMA is an integrated generator protection and control system. Ease of use, quality and cost effectiveness were the key targets when SELCO set out to design the SIGMA concept.

The SELCO S6100 SIGMA S/LS Module provides frequency control, voltage control, automatic synchronization and active/reactive load sharing. The S6100 has dedicated interfaces for both conventional and electronic governors and automatic voltage regulators. Manual control is also possible through external push buttons. The S6100 reads generators parameters from the S6000 IO/P module (connected through the CAN bus). The S6100 will also measure the Bus bar voltages across all three phases. The bus bar voltage measurements are digitally sampled by the built-in signal processor and converted to true RMS values. The S6100 will continuously do real-time calculations of derived parameters.

The S6100 can connect to generators with or without neutral. The S6100 includes voltage control, frequency control, voltage matching, automatic or manual synchronisation and automatic or manual active/reactive load sharing. The control algorithms are based on three phase measurements. Built-in relays are provided for control of conventional governors and AVR's. Isolated analogue outputs are provided for control of electronic governors and AVR's. The S6100 will work with or without droop. The S6100 can operate in parallel with the SELCO T4400 or T4800 load sharers. The RS485 MODBUS-RTU connection provides easy interfacing to SCADA systems and PLC's. Measured calculated parameters are easily accessed by any device capable of operating as a MODBUS master. Configuration parameters can also be accessed and altered through MODBUS-RTU. An RS232 connection is provided for point-to-point configuration.

The S6000 can be remotely configured by "clear text" commands issued from a standard terminal emulator (e.g. Windows HyperTerminal). The complete configuration can be stored as text files. Together with the S6000 and S6500, the S6100 will provide a simple yet powerful solution to a full scale control system. Such a system will provide protection, auto-synchronization, load sharing, indication and SCADA connectivity. A single variant supports nominal voltages in the range 63 to 690 VAC. Secondary CT current must be specified upon delivery (5 or 1 A). The S6100 is designed to comply with marine requirements. The design of the circuitry and metal casing provides the best possible protection from EMC and environmental stress. The S6100 is intended for switch board installation. Measurements are 145 x 190 x 64 mm.

## S6500 SIGMA UI Module



SIGMA is an integrated generator protection and control system. Ease of use, quality and cost effectiveness were the key targets when SELCO set out to design the SIGMA concept.

The SELCO S6500 SIGMA UI Module is a flush mountable user interface for the SIGMA range of modules. The S6500 fills the role of a flush mount digital multimeter as well as a configuration terminal. The S6500 will provide real-time readings of voltages, currents, active/reactive load, VA, frequency etc. A single S6500 can support up to 16 S6000 and S6100 modules. The S6500 can be used to monitor and alter parameters in parallel with an operating SCADA system.

The S6500 measures 144 x 144 x 75 mm.

## Functional test procedure

General performance verification is performed as follows:

1. Change to "VOLT" or "AMP" mode
2. S6500 "MENU"
3. Select "GENERATOR MODULE"
4. Select "SIGMA IO/P"->"PROTECTION"->"SHORT CIRCUIT"
5. Change "TRIP LEVEL" 0% - press "YES"
6. "C/B TRIP" & "SC" activated on S6000 & M4100
7. Change "TRIP LEVEL" 120% - press "YES"
8. Press "C/B reset" on simulator box
9. "C/B TRIP" & "SC" de-activated on S6000
10. Reset M4100's
11. Select "SIGMA IO/P"->"PROTECTION"->"OVER CURRENT"
12. Change "TRIP LEVEL" 0% - press "YES"
13. "C/B TRIP" & "OC" activated on S6000 & M4100
14. Change "TRIP LEVEL" 100% - press "YES"
15. Press "C/B reset" on simulator box
16. "C/B TRIP" & "OC" de-activated on S6000
17. Reset M4100's
18. Select "SIGMA IO/P"->"PROTECTION"->"OVER LOAD"
19. Change "TRIP LEVEL" 0% - press "YES"
20. "C/B TRIP" & "OL" activated on S6000 & M4100
21. Change "TRIP LEVEL" 100% - press "YES"
22. Press "C/B reset" on simulator box
23. "C/B TRIP" & "OL" de-activated on S6000



24. Reset M4100's
25. Select "SIGMA IO/P"->"PROTECTION"->"REVERSE POWER"
26. Change "TRIP LEVEL" 0% - press "YES"
27. "C/B TRIP" & "RP" activated on S6000 & M4100
28. Change "TRIP LEVEL" -7% - press "YES"
29. Press "C/B reset" on simulator box
30. "C/B TRIP" & "RP" de-activated on S6000
31. Reset M4100's
32. Select "SIGMA IO/P"->"PROTECTION"->"EXCITATION LOSS"
33. Change "TRIP LEVEL" 0% - press "YES"
34. "C/B TRIP" & "EL" activated on S6000 & M4100
35. Change "TRIP LEVEL" -5% - press "YES"
36. Press "C/B reset" on simulator box
37. "C/B TRIP" & "EL" de-activated on S6000
38. Reset M4100's
39. Select "SIGMA IO/P"->"PROTECTION"->"VOLTAGE ESTABLISH"
40. Change "LOWER TRIP LEVEL" 100% - press "YES"
41. "C/B TRIP" & "VE" activated on S6000 & M4100
42. Change "LOWER TRIP LEVEL" 80% - press "YES"
43. Press "C/B reset" on simulator box
44. "C/B TRIP" & "VE" de-activated on S6000
45. Reset M4100's
46. Select "SIGMA IO/P"->"PROTECTION"->"NONE ESSENTIALS 1"
47. Change "TRIP LEVEL" 0% - press "YES"
48. "NE1" activated on S6000 & M4100

49. Change "TRIP LEVEL" 100% - press "YES"
50. Press "NE reset" on simulator box
51. "NE1" de-activated on S6000
52. Reset M4100's
53. Select "SIGMA IO/P" ->"PROTECTION"->"NONE ESSENTIALS 2"
54. Change "TRIP LEVEL" 0% - press "YES"
55. "NE2" activated on S6000 & M4100
56. Change "TRIP LEVEL" 100% - press "YES"
57. Press "NE reset" on simulator box
58. "NE2" de-activated on S6000
59. Reset M4100's
60. "C/B state" of simulator box "OFF" -> "C/B" LED's "OFF"
61. Interchange phase S & T -> "PHASE" LED's "OFF" on S6000 & S6100
62. Re-establish phase S & T -> "PHASE" LED's "ON" on S6000 & S6100
63. Press "UNLOAD" on simulator box -> "UNLOAD" LED "ON" on S6100
64. Press "C/B CLOSE BLOCK" on simulator box -> "C/B BLOCK" LED "ON" on S6100
65. "C/B state" of simulator box "ON" -> "C/B" LED's "ON"
66. Press "SPEED INCR" on simulator box -> "SPEED" volt/amp on M3000 increases
67. Press "SPEED DECR" on simulator box -> "SPEED" volt/amp on M3000 decreases
68. Set "SPEED" level to 4,5V/12 mA
69. Press "VOLT INCR" on simulator box -> "VOLT" volt/amp on M3000 increases
70. Press "VOLT DECR" on simulator box -> "VOLT" volt/amp on M3000 decreases
71. Set "VOLT" level to 4,5V/12 mA
72. Change to "RELAY" mode
73. S6500 "MENU"

74. Select "GENERATOR MODULE"
75. Select "SIGMA S/LS" -> "SYSTEM" -> "GOVERNOR" -> "CONVENTIONAL" -> "YES"
76. Activate "DECR" or "INCR" on simulator box -> "SPEED" or "VOLT" relay's toggle
77. Re-establish "VOLT" or "AMP" mode
78. Remove 24 VDC from "BACKUP SUPPLY" from S6000, S6100 & S6500
79. "ALARM" LED's & "ALARM" relay's of S6000 & S6100 activated
80. "POWER 2" LED on S6500 "OFF"
81. Re-establish 24 VDC supply -> Alarms of & power LED's "ON"
82. Reset M4100's


***Annex 4***

***Test record sheets – Conducted emissions***

***(24 pages)***


**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6500, UI  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 9  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6500, UI  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 10  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6500, UI  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 11  
Start of Test: 2003-08-19



**DELTA Electronics Testing, EMC Section**


EUT: SIGMA S6500, UI  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 12  
Start of Test: 2003-08-19






**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 13  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 14  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 15  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 16  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 17  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 18  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 19  
Start of Test: 2003-08-19



**DELTA Electronics Testing, EMC Section**


EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: EN 55011 A. EN 55022 A  
Comment: Sheet 20  
Start of Test: 2003-08-19






**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6500, UI  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533. IEC 60945  
Comment: Sheet 21  
Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6500, UI  
 Manufacturer: Selco A/S  
 Operating Condition: Line no.: +24 VDC. Mains power  
 Test Site: EMC-5  
 Operator: HEN - E501273  
 Test Specification: E10. IEC 60533. IEC 60945  
 Comment: Sheet 22  
 Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6500, UI  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533. IEC 60945  
Comment: Sheet 23  
Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6500, UI  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533. IEC 60945  
Comment: Sheet 24  
Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533. IEC 60945  
Comment: Sheet 25  
Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533.  
Comment: Sheet 26  
Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533.  
Comment: Sheet 27  
Start of Test: 2003-08-20



**DELTA Electronics Testing, EMC Section**


EUT: SIGMA S6000, IO/P  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533.  
Comment: Sheet 28  
Start of Test: 2003-08-20






**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533.  
Comment: Sheet 29  
Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Mains power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533.  
Comment: Sheet 30  
Start of Test: 2003-08-20




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: +24 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533.  
Comment: Sheet 31  
Start of Test: 2003-08-20



**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6100, S/LS  
Manufacturer: Selco A/S  
Operating Condition: Line no.: 0 VDC. Backup power  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533.  
Comment: Sheet 32  
Start of Test: 2003-08-20




***Annex 5***

***Test record sheets – Radiated emissions***

***(8 pages)***


**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
 Manufacturer: Selco A/S  
 Operating Condition: Ant 0 deg  
 Test Site: EMC-5  
 Operator: HEN - E501273  
 Test Specification: E10. IEC 60533. IEC 60945  
 Comment: Sheet 7  
 Start of Test: 2003-08-19



**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
 Manufacturer: Selco A/S  
 Operating Condition: Ant 90 deg  
 Test Site: EMC-5  
 Operator: HEN - E501273  
 Test Specification: E10. IEC 60533. IEC 60945  
 Comment: Sheet 8  
 Start of Test: 2003-08-19




**MEASUREMENT RESULT: "mfield\_0001\_fin QP"**

2003 08 19 15:34

| Frequency<br>MHz | Level<br>dBµV/m | Transd<br>dB | Limit<br>dBµV/m | Margin<br>dB | Loop | Azimuth<br>deg |
|------------------|-----------------|--------------|-----------------|--------------|------|----------------|
| 0.895000         | 45.60           | 20.2         | 47.8            | 2.2          | 90 d | 160.00         |
| 1.580000         | 44.80           | 20.2         | 45.5            | 0.7          | 90 d | 187.00         |

**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
 Manufacturer: Selco A/S  
 Operating Condition: Ant. 1 m vertical. 24 VDC  
 Test Site: EMC-5  
 Operator: HEN - E501513/E501273  
 Test Specification: E10. IEC 60533  
 Comment: Sheet 1  
 Start of Test: 2003-09-25



**MEASUREMENT RESULT: "Maximizing\_fin QP"**


2003 09 25 15:06

| Frequency<br>MHz | Level<br>dBµV/m | Transd<br>dB | Limit<br>dBµV/m | Margin<br>dB | Height<br>cm | Azimuth<br>deg | Polarisation |
|------------------|-----------------|--------------|-----------------|--------------|--------------|----------------|--------------|
| 46.000000        | 33.80           | 11.4         | 57.9            | 24.1         | 101.0        | 77.00          | VERTICAL     |
| 156.700000       | 20.20           | 13.7         | 24.0            | 3.8          | 110.0        | 0.00           | VERTICAL     |
| 499.980000       | 40.80           | 22.2         | 54.0            | 13.2         | 169.0        | 53.00          | HORIZONTAL   |
| 549.980000       | 42.10           | 24.7         | 54.0            | 11.9         | 123.0        | 199.00         | VERTICAL     |
| 599.980000       | 38.60           | 24.3         | 54.0            | 15.4         | 111.0        | 2.00           | VERTICAL     |
| 649.980000       | 40.00           | 24.8         | 54.0            | 14.0         | 110.0        | 327.00         | VERTICAL     |




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
Manufacturer: Selco A/S  
Operating Condition: Ant. 3 m horizontal. 24 VDC  
Test Site: EMC-5  
Operator: HEN - E501513/E501273  
Test Specification: E10. IEC 60533  
Comment: Sheet 2  
Start of Test: 2003-09-25




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
Manufacturer: Selco A/S  
Operating Condition: Ant 1 m vertical  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533  
Comment: Sheet 5  
Start of Test: 2003-08-19




**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
Manufacturer: Selco A/S  
Operating Condition: Ant 3 m horizontal  
Test Site: EMC-5  
Operator: HEN - E501273  
Test Specification: E10. IEC 60533  
Comment: Sheet 6  
Start of Test: 2003-08-19



**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
 Manufacturer: Selco A/S  
 Operating Condition: Ant 1 m vertical  
 Test Site: EMC-5  
 Operator: HEN - E501273  
 Test Specification: EN 55011 A. EN 55022 A  
 Comment: Sheet 1  
 Start of Test: 2003-08-19




**MEASUREMENT RESULT: "Maximering\_fin QP"**

2003 08 19 11:37

| Frequency<br>MHz | Level<br>dBµV/m | Transd<br>dB | Limit<br>dBµV/m | Margin<br>dB | Height<br>cm | Azimuth<br>deg | Polarisation |
|------------------|-----------------|--------------|-----------------|--------------|--------------|----------------|--------------|
| 46.700000        | 37.10           | 10.8         | 40.0            | 2.9          | 101.0        | 274.00         | VERTICAL     |
| 76.900000        | 21.30           | 8.3          | 40.0            | 18.7         | 391.0        | 0.00           | HORIZONTAL   |
| 149.990000       | 27.90           | 12.7         | 40.0            | 12.1         | 101.0        | 0.00           | VERTICAL     |
| 160.000000       | 27.30           | 11.7         | 40.0            | 12.7         | 101.0        | 358.00         | VERTICAL     |
| 199.990000       | 36.20           | 11.4         | 40.0            | 3.8          | 376.0        | 114.00         | HORIZONTAL   |
| 399.990000       | 44.00           | 18.2         | 47.0            | 3.0          | 283.0        | 165.00         | HORIZONTAL   |
| 449.980000       | 44.50           | 19.4         | 47.0            | 2.5          | 177.0        | 291.00         | HORIZONTAL   |
| 499.980000       | 46.20           | 20.4         | 47.0            | 0.8          | 190.0        | 178.00         | HORIZONTAL   |

**DELTA Electronics Testing, EMC Section**

EUT: SIGMA S6000,IO/P. SIGMA S6100,S/LS. SIGMA S6500,UI  
 Manufacturer: Selco A/S  
 Operating Condition: Ant 4 m horizontal  
 Test Site: EMC-5  
 Operator: HEN - E501273  
 Test Specification: EN 55011 A. EN 55022 A  
 Comment: Sheet 2  
 Start of Test: 2003-08-19



***Annex 6***

***Explanatory notes regarding modifications (from Selco A/S)***

***(2 pages)***

## **Modifications**

The following modifications were made before the SIGMA modules passed the conducted radio frequency interference testing, the surge testing, the electrostatic discharge testing and the radiated emission measurements.

### **S6000:**

- Varistor between Primary supply kl.1 (+24V) and earth
- Varistor between Primary supply kl.2 (GND) and earth
- Varistor between Primary supply kl.1 (+24V) and Primary supply kl.2 (GND)
- Varistor between Backup supply kl.1 (+24V) and earth
- Varistor between Backup supply kl.2 (GND) and earth
- Varistor between Backup supply kl.1 (+24V) and Backup supply kl.2 (GND)
- 1nF capacitor placed between GND\_MH and earth on MCU board
- 100nF capacitor placed between analog outputs kl.1 and earth
- 100nF capacitor placed between analog outputs kl.2 and earth
- 100nF capacitor placed between analog outputs kl.4 and earth
- 100nF capacitor placed between analog outputs kl.5 and earth
- 100nF capacitor placed between analog outputs kl.7 and earth
- 100nF capacitor placed between analog outputs kl.8 and earth

### **S6100:**

- Varistor between Primary supply kl.1 (+24V) and earth
- Varistor between Primary supply kl.2 (GND) and earth
- Varistor between Primary supply kl.1 (+24V) and Primary supply kl.2 (GND)
- Varistor between Backup supply kl.1 (+24V) and earth
- Varistor between Backup supply kl.2 (GND) and earth
- Varistor between Backup supply kl.1 (+24V) and Backup supply kl.2 (GND)

- 1nF kapacitor placed between GND\_MH and earth on MCU board
- 100nF kapacitor placed between analog outputs kl.1 and earth
- 100nF kapacitor placed between analog outputs kl.2 and earth
- 100nF kapacitor placed between analog outputs kl.5 and earth
- 100nF kapacitor placed between analog outputs kl.6 and earth

**S6500:**

- Varistor between Primary supply kl.1 (+24V) and earth
- Varistor between Primary supply kl.2 (GND) and earth
- Varistor between Primary supply kl.1 (+24V) and Primary supply kl.2 (GND)
- Varistor between Backup supply kl.1 (+24V) and earth
- Varistor between Backup supply kl.2 (GND) and earth
- Varistor between Backup supply kl.1 (+24V) and Backup supply kl.2 (GND)
- SW2 removed