

# TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No.	<b>91 362 - 89 HH</b>
Company	<b>Littelfuse Selco A/S</b> <b>Betonvej 10</b> <b>4000 Roskilde, DENMARK</b>
Product Description	<b>Paralleling Relay</b>
Type	<b>T5000</b>
Environmental Category	<b>C, EMC2</b>
Technical Data / Range of Application	<b>Paralleling Relay - Type T 5000</b> <b>Rated Voltage</b> <b>100 - 660 V AC, 24V DC</b> <b>Voltage Tolerance</b> <b>-30 - +10 %</b> <b>Rated Frequency</b> <b>45 - 65 Hz</b>  <b>Contact Rating</b> <b>380V AC / 8A   2000VA/ 150W DC</b>
Test Standard	<b>Guidelines for the Performance of Type Approvals VI-7-2, Edition 2012.</b>
Documents	<b>Test report : LK-Laboratory Test Report R 860729-02E</b> <b>Data Sheet T 5095</b>
Remarks	<b>This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007.</b>

Valid until **2017-06-28**

Page **1 of 1**

File No. **I.L.03**

**Hamburg, 2014-09-25**

Type Approval Symbol



**DNV GL**

  
Marco Rinkel

  
Jens Dietrich