

TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No.	42 214 - 01 HH
Company	Littelfuse Selco A/S Betonvej 10 4000 Roskilde, DENMARK
Product Description	Shut Down Unit M0600, Universal PC Board M0700-50
Type	M0600, M0700-50
Environmental Category	D, EMC2
Technical Data / Range of Application	Rated supply voltage: 24 VDC Shut Down Unit M0600: 5 Inputs: Overspeed, Spare, Low lub Oil Pressure, Running, Stopping 1 Output: NO/ NC relay to activate the stop valve or the safety shut down Universal PC Board M0700-50: For connection of resistors or diodes.
Test Standard	Guidelines for the Performance of Type Approvals, Chapter 2- Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2), Edition 2012
Documents	Test report : DELTA-K251196-7, dated 9.1.2001; DANAK-198611.
Remarks	This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007.

Valid until **2017-06-28**

Page **1 of 1**

File No. **I.A.03**

Hamburg, 2014-11-03

Type Approval Symbol



i.A. 
Arne Schaarman

i.A. 
Harald Amberger