

# TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No.	<b>94 548 - 90 HH</b>
Company	<b>Littelfuse Selco A/S</b> <b>Betonvej 10</b> <b>4000 Roskilde, DENMARK</b>
Product Description	<b>3-Phase Overcurrent Relay</b>
Type	<b>T2200</b>
Environmental Category	<b>C</b>
Technical Data / Range of Application	<b>3-Phase Overcurrent Relay - Type T 2200</b> <b>Rated Voltage</b> 100 - 660 V AC, 24V DC <b>Voltage Tolerance</b> -40 - +10 <b>Nominal Current</b> 5A <b>Continuous current</b> 2 x In  <b>Overcurrent Range</b> 0.5 - 1.4 x In <b>Time delay</b> 3 - 30s  <b>Contact Rating</b> 380V AC / 8A 2000VA / 150W DC
Test Standard	<b>GL Guidelines for the Performance of Type Approvals, Chapter 2 - Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2), Edition 2012</b>
Documents	<b>Test report : Data Sheet T 2295</b>
Remarks	<b>This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007.</b>

Valid until **2017-06-28**

Page **1 of 1**

File No. **I.L.02**

**Hamburg, 2014-11-03**

Type Approval Symbol



*i.A.*  
Arne Schaarmann

*i.A. H.*  
Harald Amberger