

TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No. **94 549 - 90 HH**

Company **Littelfuse Selco A/S**
Betonvej 10
4000 Roskilde, DENMARK

Product Description **3-Phase Short Circuit Relay**

Type **T2300**

Environmental Category **C**

Technical Data /
 Range of Application **3-Phase Short Circuit Relay - Type T 2300**

Rated Voltage 100 - 660 V AC, 24V DC
Voltage tolerance -40 - +10 %
Nominal Current 5A

Continuous Current 2 x In
Overcurrent Range 0.5 - 1.4 x In
Time Delay 3 - 30s
Short-Circuit Range 1.0 - 4.0 x In
Time Delay 0.1 - 1.0s

Contact Rating 380V AC / 8A 2000VA / 150W DC

Test Standard **GL Guidelines for the Performance of Type Approvals, Chapter 2 - Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2), Edition 2012**

Documents **Test report : Data Sheet T 2395**

Remarks **This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007.**

Valid until **2017-06-28**

Page **1 of 1**

File No. **I.L.02**

Hamburg, 2014-11-03

Type Approval Symbol



i.A.

 Arne Schaarmann

i.A. H.

 Harald Amberger