

TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No.	94 550 - 90 HH
Company	Littelfuse Selco A/S Betonvej 10 4000 Roskilde, DENMARK
Product Description	3-Phase Overcurrent Relay
Type	T2400
Environmental Category	C
Technical Data / Range of Application	3-Phase Overcurrent Relay - Type T 2400 Rated Voltage 100 - 660 V AC, 24V DC Voltage Tolerance -40 - +10 % Nominal Current 5A Continuous current 2 x In Overcurrent range 0.5 - 1.4 x In Time Delay 3 - 30s Contact Rating 380V AC / 8A 2000VA / 150W DC
Test Standard	GL Guidelines for the Performance of Type Approvals, Chapter 2 - Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2), Edition 2012
Documents	Test report : Data Sheet T 2495
Remarks	This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007.

Valid until **2017-06-28**

Page **1 of 1**

File No. **I.L.02**

Hamburg, 2014-11-03

Type Approval Symbol



DNV GL

i.A.
Arne Scheeremann

i.A.H.
Harald Amberger