

TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.


| | |
|------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Certificate No. | 55 462 - 90 HH |
| Company | Littelfuse Selco A/S Betonvej 10 4000 Roskilde, DENMARK |
| Product Description | Start-Stop Relay |
| Type | T2600 |
| Environmental Category | C |
| Technical Data / Range of Application | Start-Stop Relay - Type T 2600 Rated Voltage 100 - 660 V AC, 24V DC Voltage Tolerance -40 - +10 % Nominal Current 1A/ 5A Start Current 0.3 - 1.2 x In Stop Current 0.2 - 0.8 x In Time Delay 1 - 10 min Contact Rating 380V AC / 8A 2000VA/ 150W DC |
| Test Standard | GL Guidelines for the Performance of Type Approvals, Chapter 2 - Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2), Edition 2012 |
| Documents | Test report : Data Sheet T2695 |
| Remarks | This certificate is issued on the basis of GL Guidelines for the Performance of Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007. |

Valid until **2017-06-28**
Page **1 of 1**
File No. **I.L.02**
Hamburg, 2014-11-03

Type Approval Symbol



i.A. 
Arne Schaarmann

i.A. 
Harald Amberger