



TYPE APPROVAL CERTIFICATE

Certificate No:
TAA000014M
Revision No:
1

This is to certify:

That the Monitoring System

with type designation(s)
Alarm monitor - M4200

Issued to

SELCO ApS
Roskilde, Sjælland, Denmark

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes:

Temperature	B*
Humidity	B
Vibration	B
EMC	B
Enclosure	Required protection according to the Rules shall be provided upon installation on board

* Cold temperature test to -15°C carried out

Issued at **Høvik** on **2022-11-07**

This Certificate is valid until **2026-12-31**.

DNV local unit: **Denmark CMC**

Approval Engineer: **Ståle Sneen**

for **DNV**



Digitally Signed By: Elter, Frederik Tore
Location: DNV Høvik, Norway

Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

SELCO Alarm Monitor M4200

The following software is included in the Type Approval:

Firmware 110617

Approval conditions

The following documentation of the actual application is to be submitted for approval in each case:

- Reference to this Type Approval Certificate
- System block diagram
- Power supply arrangement (may be part of the System block diagram)

The Type Approval covers hardware and software listed under Product description.

As long as the units are covered by the Type Approval, a product certificate according to Pt.4 Ch.9 Sec.1 will not be required. Correct configuration and set up for each delivery to be tested during commissioning after installation.

Clause for application software control:

All changes in software are to be recorded as long as the system is in use on board. The records of all changes are to be forwarded to DNV for evaluation and approval.

Major changes in the software are to be approved before being installed in the computer.

Certification of Application Functions may be required for the particular vessel.

Type Approval documentation

Ring binder "DNV M4200 Type Approval Documents", containing:

1. Data sheet (M4295-72E)
2. User Manual (revision 25.04.2007)
3. Delta test report (DANAK-198778, dated 12 June 2007)
4. Mechanical drawings (Front and rear layout, dated 06 Oct 2006)

Updated data sheet (M4295-84UK)

Updated User Manual dated 2017-03-07

Supplementary test report of M4200 according to parts of IACS UR E10 Rev.7 (P20-0110-7 rev.1, dated 2020-10-28)

Type approval renewal assessment report for TAA000014M, Denmark CMC 2022-08-23.

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

For the bridge mounted components, the 'Acoustic noise and signals' and the 'Compass safe distance' were measured according to sections 11.1 and 11.2 of IEC 60945, 4th edition (2002).

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE