

Certificate No: **TAE000037C**

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Instrument for Switchboard

with type designation(s)

T2000, Reverse Power Relay, T2200, T2400, 3-Phase Overcurrent Relay, T2300, 3-Phase Short Circuit Relay, T2500, 3-Phase Overcurrent and Short Circuit Relay, T2600, Start-Stop Relay, T2900, 3-Phase Differential Relay, T7900, Electronic Potentiometer

Issued to

SELCO ApS Roskilde, Denmark

is found to comply with

DNV GL rules for classification - Ships, offshore units, and high speed and light craft

Application:

Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.

Issued at Høvik on 2019-08-15

This Certificate is valid until **2024-08-14**. DNV GL local station: **Copenhagen**

Approval Engineer: Georgy Abramenko

for **DNV GL**Digitally Signed By: Trond Sjåvåg
Location: DNV GL Høvik, Norway

Trond Sjåvåg Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 1 of

Job Id: **262.1-029923-1** Certificate No: **TAE000037C**

Product description

1 Todace accompany					
Product	Rated voltage with voltage tolerance	Nominal current	Overcurrent range	Time delay	Contact rating/ Start - Stop current
	3	Current	runge		Start Stop carrent
T2000	100 - 660VAC, -50 - +10%	1A/ 5A	-	0.2s	200\/4.5/.04
T2200					380VAC/ 8A 2000VA/ 150W DC
T2300	100 – 660VAC, 24VDC	5A	0.5-1.4xIn	3-30s	2000VA/ 130W DC
T2400	-40 - +10%				
T2500		1A/ 5A			
T2600			-	1-10min	0.3-1.2xIn/ 0.2-0.8xIn
T2900	Max. 660V,		Trip level:	1-10sec	AC: 400V, 5A, 2000VA
12900	voltage range: 60-110%		0.04-0.4In	1-10560	DC: 150V, 5A, 150W
T7900	8-36V AC/DC				

Application/Limitation

Equipment is certified to be used in following environmental conditions according to DNV-GL CG-0339:

Temperature B Humidity B Vibration A

Type Approval documentation

Datasheets referred in LGL certificates, NPS job 262.1-029923-1

Tests carried out

Applicable tests according to DNV-GL CG-0339 standard.

Marking of product

SELCO, type designation

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 2 of 2